



## BOROUGH OF HARVEY CEDARS Water/Sewer Department

### New Water Service/CO Requirements

New Water Service/ CO Line Installation Requirements (items 1 through 9)

Existing Water Service Reconnects Requirements (items 5 through 9)

1. Size - 3/4 inch minimum.
2. Saddle - Double strap stainless steel or bronze only CC thread.
3. Corporation – CC thread inlet, flared or compression outlet.
4. Service line - "K" copper tubing or pp.
5. Curb Stops – Services are to have a curb stop and curb box on the street side of meter pit.
6. Meter Pits should be set close to the property line street side. Top of yolk set no less than 36 inches from finish grade.
7. Meter Pit Type – "Mueller/Hunt EZ-Setter" Thermal-Coil Meter Box or equal.
  - A To fit 5/8 X 3/4 inch meter unless larger service is installed.
  - B Box diameter 18 inch
  - C Meter inlet - Lockwing angle ball valve (full port)
  - D Meter outlet – A.S.S.E. Dual check valve.
  - E Insulating pad – 4 inch thickness to be included
  - F Lid to be Side locking (No Hole in center)
8. Meter Pit Fittings – To be all brass, flared or compression.
9. Meter – 3/4X5/8 meters will be installed by HC Water Dept. at time of CO approval. Larger size meters are to be supplied by Owner/Contractor - Contact Boro Superintendent for specifications.

**Note:**

- a) No water service is to be buried less than 36 inches deep.
- b) No taps are to be made within 12 inches of water main fittings or couplings.
- c) No Direct taps on water mains or taps on top of main. Shut off valve must face up.
- d) No iron pipe, or similar fittings.
- e) Service line must be laid from main to meter yoke without any joints.
- f) Meter box is to be set to finish grade of property.
- g) 48 hours notice is to be made to Water Dept. for inspection Mon. Through Friday, 7am-3pm, 609-494-6905.
- h) No installations are to be made weekends (Saturday or Sunday) or Holidays.
- i) Road opening permits are required before opening of road trench.

### New Sewer and CO Service Line Installation Requirements (items 1 through 5)

Sewer Service Reconnects Requirements (items 3 through 5)

1. Size - 4 inch minimum.
2. Lateral line – PVC Sewer pipe SDR-35.  
Joints shall be bell and spigot type with rubber ring seal.
3. Clean-out – A 4 inch clean-out and stack fitting shall be installed at property line.  
Stack pipe should terminate 10 inches below finish grade.
4. Clean-out Cap – Cap should be of a type that will minimize intrusion of water and dirt yet easily removed by hand.
5. Clean-out Box – All Metal (no plastic bodies) 5 ¼ inch Slide Type box and lid marked "SEWER". (Tyler 564A or equal)  
Installed to finish grade and centered on sewer clean-out.

**Note:**

- a) 48 hours notice is to be made to Water/Sewer Dept. for inspections, Call 609-494-6905, Mon. to Fri. 7am-3 pm.
- b) No installations are to be made weekends (Saturday or Sunday) or Holidays.
- c) Road opening permits are required before opening of road trench